

OSCEOLA FORCE MAIN AND ST. CLAIR LIFT STATION IMPROVEMENTS

ADDENDUM NO. 1

DATE: November 13, 2023

Bid Number: 142173504

***This addendum forms a part of the Specifications and modifies the original Document as noted. Acknowledge receipt of this Addendum in the appropriate portion of Section 00300 with the submitted bid. Failure to do so may subject the proposer to disqualification.***

1. Do you have Engineer estimating for the Project?

***Response: The Engineer's estimate is \$645,000.00.***

2. Need diameter of the Lift Station.

***Response: Diameter of wet well is 8' and shown on Sheet 06 in the plans.***

3. Need depth of the Lift Station.

***Response: Depth of wet well is shown on Sheet 11 in the plans.***

ATTACHMENTS:

END OF SECTION